



DEPARTMENT OF PERMITTING SERVICES

Marc Elrich
County Executive

Hadi Mansouri
Acting Director

April 21, 2020

Mr. Abhijit Subedi
Greenman-Pedersen, Inc. (GPI)
11000 Broken Land Parkway, Suite 500,
Columbia, MD 21044

Re: **COMBINED STORMWATER MANAGEMENT
CONCEPT/SITE DEVELOPMENT
STORMWATER MANAGEMENT PLAN** for
Rehabilitation of Bridge-0043
Preliminary Plan #: NA
SM File #: 285831
Tract Size/Zone: 0.50
Total Concept Area: 0.50 ac
Lots/Block: NA
Parcel(s): NA
Watershed: Little Monocacy

Dear Mr. Subedi:

Based on a review by the Department of Permitting Services Review Staff, the stormwater management concept for the above-mentioned site is **acceptable**. The stormwater management concept proposes to meet required stormwater management goals via scour protection and stream bed stabilization.

The following items will need to be addressed during the detailed sediment control/stormwater management plan stage:

1. A floodplain delineation study or exemption through MD DNR Policy 93-01 In-Kind Bridge Culvert Replacement will be required prior to sediment control plan approval. A floodplain district permit is required for this bridge replacement.
2. An engineered sediment control plan must be submitted for this development.
3. All filtration media for manufactured best management practices, whether for new development or redevelopment, must consist of MDE approved material.

This list may not be all-inclusive and may change based on available information at the time.

Payment of a stormwater management contribution in accordance with Section 2 of the Stormwater Management Regulation 4-90 **is not required**.

This letter must appear on the sediment control/stormwater management plan at its initial submittal. The concept approval is based on all stormwater management structures being located outside of the Public Utility Easement, the Public Improvement Easement, and the Public Right of Way unless specifically approved on the concept plan. Any divergence from the information provided to this office; or additional information received during the development process; or a change in an applicable



255 Rockville Pike, 2nd Floor, Rockville, Maryland 20850 | 240-777-0311
www.montgomerycountymd.gov/permittingervices

Mr. Abhijit Subedi
April 21, 2020
Page 2 of 2

Executive Regulation may constitute grounds to rescind or amend any approval actions taken, and to reevaluate the site for additional or amended stormwater management requirements. If there are subsequent additions or modifications to the development, a separate concept request shall be required.

If you have any questions regarding these actions, please feel free to contact Bill Musico at 240-777-6340.

Sincerely,



Mark C. Etheridge, Manager
Water Resources Section
Division of Land Development Services

MCE: WJM

cc: SM File # 285831

ESD: Required/Provided 0.00 cf / 0.00 cf
PE: Target/Achieved: 0.00"/0.00"
STRUCTURAL: 0.00 cf
WAIVED: 0.00 ac.